Response to Comments

Comment Deadline: April 29, 2019 by 5:00 p.m.

Tentative National Pollutant Discharge Elimination System (NPDES) and Waste Discharge Requirements (WDRs) Order R7-2019-0005, Niland County Sanitation District, Niland Wastewater Treatment Plant

Comment Letter #	Date	Commenter	Affiliation
Email 1	4/29/2019	Pascal Mues	USEPA – Environmental Engineer

Changes proposed in response to comments made on 4/29/19 will be incorporated into the tentative WDRs as shown in the errata sheet prepared on 5/2/19.

Comment Locat # the V	ation in WDR	Comment	Response
1 Page	e numbers	For Niland, the same numbering error occurred but with A-# and C-# sections instead of A- and B-#.	These editorial changes will be made in the adopted version.
Fact S III.D. Wate on Cle Wate 303(c) Ratio Efflue Limita IV.C.3 Deter the N WQB Priori	er Act (d) List. onale for uent tations, .3. ermining Need for BELs for	My most significant issue is addressing 303(d) listed impairments more clearly and explicitly. Given the long list of chemical impairments for the New River, Salton Sea, and Imperial Valley Drains (Fact Sheet section III.D), I would have liked to see a clear statement that each facility's priority pollutant scans (and other monitoring data) were reviewed for the presence/absence of each of the impairing pollutants- most of them do not appear to be addressed anywhere in the permit record outside of the mention of the impairment listings. The idea that nutrient impairments would not need to be addressed in the context of a WWTP discharge, for example, warrants specific explanation, especially in light of the basin plan's prohibition of "biostimulatory substances". Similar issues might arise for addressing the impairments for low DO and "sediment".	The draft NPDES permit/WDRs do contain a reasonable potential analysis (RPA) for all pollutants for which there are water quality-based effluent limitations (WQBELs) in the permit, including for the 303(d) List of impairing pollutants. For clarity, staff recommends adding the following language in bold to the attachment F Fact Sheet section IV.C.3. second to the last paragraph: "Except for chlorodibromomethane, the discharge from the Facility does not contain any of the 303(d)-List, impairing pollutants for the receiving water at detectable levels."

3	Attachment F.	In Niland's case, the claim that the TSS	According to the Imperial Valley Drains Sedimentation/Siltation TMDL
	Fact Sheet,	effluent limitations comply with the	approved by USEPA on September 30, 2005, the TMDL establishes a numeric
	III.D. Impaired	sediment TMDL's WLA needs to be	target of 200 mg/L for Total Suspended Solids (TSS). The TSS loading rate for
	Water Bodies	demonstrated. When I back-calculate from	the Facility is 152.3 tons per year shown the detailed calculation below:
	on Clean	the TBEL TSS limits, I get [(396 lbs/day)*(365	
	Water Act	days/year)*(1 ton/2000 lbs)] = 72.27	(200mg/L)*(1kg/10^6mg)*(3.78541L/gal)* 500000 gal/day)*(ton/907.185kg)
	303(d) List.	tons/year, well in excess of the stated WLA	= (0.41723 ton/day) *(365 days/Yr) = 152.3 tons/Yr
	Rationale for	of 11.4 tons per year. Assertion of	
	Effluent	compliance with the WLA isn't enough when	The Waste Load Allocation (WLA) stated an incorrect loading rate of 11.4 tons
	Limitations	the numbers show that kind of disparity.	per year. The correct WAL is 152.3 tons/year, as shown above. Therefore, the
		One potential way to address this question	TBEL for TSS (72.27 tons/year) is less than TMDL WLA of 152.3 tons/year. As
		for most other parameters would be to add	such, staff does not recommend changing the TSS effluent limitation in
		some additional discussion to the numbers	response to this comment, but does recommend correcting the error in the
		presented in table F-3 and how they are	identified loading rate.
		consistent with the requirements for	
		discharging to a water listed as impaired for	Under Attachment F, Fact Sheet, Section II.D., Imperial Valley Drains, staff
		those substances	recommends replacing "loading rate (11.4 tons per year)" with "with numeric
			target of 200 mg/L (annual average)."
4	Attachment F.	Given the pattern of eliminating narrative	The removal of narrative TDS effluent limitation will not affect the quality of
	Fact Sheet,	TDS limits in favor of only keeping the	the discharge or degrade the receiving waters.
	IV.D.1. anti-	numeric receiving water limits, I would like	
	backsliding	to see (separate from these permit issuance	The "narrative" TDS effluent limitation in the prior Order (R7-2014-0001) was
	Requirements	documents, and on a whole-board scale) a	written as a receiving water limitation, with compliance measured as the
	IV.D.2.	data table on which permits have had that	discharge not causing the concentration of TDS in the receiving water to
	Determining	TDS narrative limit removed in their most	exceed an annual average concentration of 4,000 mg/l or a maximum daily
	the Need for	recent reissuances, and what receiving	concentration of 4,500 mg/l. This exact same requirement is still retained as a
	WQBELs for	water limits were implemented in each case.	receiving water limitation. Accordingly, the removal of the TDS "narrative"
	Priority -	I think we'd want to be able to demonstrate	effluent limitation will not result in any less stringent requirements in the
	Pollutants	consistency (as well as protectiveness) since	permit.
		implementation of RW limits can be	Chaff is because to consult with FDA fourth on on this issue
		challenging, especially in the context of	Staff is happy to work with EPA further on this issue.
		receiving waters which may have flow	
		interruptions or other drought-driven	
		effects over the life of the permits.	
	1		